



कार्यालय—उपायुक्त, सांगानेर जोन, नगर निगम जयपुर  
(सांगानेर स्टेडियम वाली रोड, गर्ल्स स्कूल के पास)

क्रमांक : एफ- 53/डी. सी/एसएनजैड/17/ 218


दिनांक : 31/07/2017

भारतीय विद्याभवन विद्याश्रम  
प्रताप नगर सांगानेर,  
जयपुर।

प्रमाण –पत्र

प्रमाणित किया जाता है कि भारतीय विद्याभवन विद्याश्रम प्रताप नगर सांगानेर जयपुर पर परिसर में सफाई व्यवस्था , शुद्ध पीने के पानी की व्यवस्था, शौचालयों की सफाई व कमरों में रोशनी निर्धारित मापदण्डों के अनुसार पायी गयी।

अतः 2017-2018 तक का स्वच्छता प्रमाण पत्र दिया जाता है।

  
स्वास्थ्य अधिकारी  
वरिष्ठ स्वास्थ्य अधिकारी जयपुर  
सांगानेर जोन नगर निगम  
सांगानेर जोन  
नगर निगम जयपुर



**OFFICE OF THE CHIEF CHEMIST  
PUBLIC HEALTH ENGINEERING DEPARTMENT, RAJASTHAN, JAIPUR**

**REPORT OF THE CHEMICAL EXAMINATION OF WATER**

Report No.: Raj/DW(Chem)/2017-18/ 1098

Dated: 11/5/17

Issued To,

**The Principal  
Bhartya Vidya Bhavan Vidyashram  
Pratap Nagar**

*The sample was not collected  
by this laboratory*

District: Jaipur  
Block/City: Jaipur City

*Not Valid for Water  
Quality Legal Cases*

Ref_ID :	5	Lab Sample No. :	9	10
Reference : Your Letter No. :	D025	Source :	Treated	TW
Reference Dated :	12/04/2017	Source Location :	B.V. B.,Vidyashram Pratap Nagar	B.V. B.,Vidyashram Pratap Nagar
Date of Receipt :	12/04/2017	Habitation/Ward No. :	Jaipur	Jaipur
Name of Sample Taker :	RK Sharma	Village/Colony/Town :	Jaipur	Jaipur
Desig. of Sample Taker :	Staff	Gram Panchayat/City Area :	Jaipur City	Jaipur City
GA-55 Book No. :	035871	Date of Collection :	12/04/2017	12/04/2017
GA-55 Receipt No. :	0002	Date of Examination :	13/04/2017	13/04/2017
Amount in Rs. :	1400.00			
<b>IS-10500:2012</b>				
Test Parameters	Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	Test Values	
1 pH	6.5 to 8.5	No Relaxation	7.6	7.9
2 Turbidity(NTU)	5	15	Nil	Nil
3 Colour (Hazen Unit)	1	5	None	None
4 Odour	Unobjectionable	-	UO	UO
5 Total Alkalinity (as CaCO <sub>3</sub> )	200	600	50	880
6 Total Hardness (as CaCO <sub>3</sub> )	300	600	30	170
7 Calcium (as Ca <sup>++</sup> )	75	200	4	80
8 Magnesium (as Mg <sup>++</sup> )	30	100	5	90
9 Chloride (as Cl <sup>-</sup> )	600	1000	20	90
10 Sulphate (as SO <sub>4</sub> <sup>-2</sup> )	200	400	4	16
11 Nitrates (as NO <sub>3</sub> <sup>-</sup> )	45	No Relaxation	6	51
12 Fluoride (as F <sup>-</sup> )	0.80	1.50	0.11	1.50
13 Total Dissolved Solids	500	2000	154	1771
14 Residual Chlorine	0.2	0.5	-	-

*[Signature]*  
Superintending Chemist  
PHED Lab Jaipur

Dated:

Report No.: Raj/DW(Chem)/2017-18/

Copy to:

- 1 The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.
- 2 The Executive Engineer, PHED Division, .....
- 3

Superintending Chemist