



नगर निगम जयपुर ग्रटर जयपुर

(पण्डित दीनदयाल उपाध्याय भवन, लालकोठी, टॉक रोड जयपुर-15)

क्रमांक :- एफ.31()/मुख्य. स्वास्थ्य अधिकारी/ 2021/182 दिनांक :- 24-6-2021

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by by Dr. Rashmi Kankaria, Chief Health Officer from Nagar Nigam Greater Jaipur inspected the Bharatiya Vidya Bhavan Vidyashram, Pratap Nagar, Jaipur and found that the Bharatiya Vidya Bhavan Vidyashram, has safe drinking water facilities for the student and members of staff of the institution, School is maintaining the hygienic sanitation condition in the building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

This Certificate is valid upto 31st Dec, 2021

(Dr. Rashmi Kankaria)

Chief Health Officer

Nagar Nigam Greater Jaipur
नगर निगम ग्रटर, जयपुर

To,

**The Principal,
Bharatiya Vidya Bhavan Vidyashram,
Pratap Nagar, Jaipur**

OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2020-2021/ 12082

Date: 18/3/21

To,
 Bhartiya Vidya Bhawan Vidyashram,
 Pratap nagar,
 Jaipur

The Sample was not Collected
 by this Laboratory


Not Valid for water
 quality i Legal Cases

Date of Receipt: 09.03.2021

Particulars	value as per I.S.:10500/2012		RO Water, Bhartiya Vidya Bhawan Vidyashram	TW Water, Bhartiya Vidya Bhawan Vidyashram
	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	Jaipur	Jaipur
Village / Town			Jaipur	Jaipur
Date of Collection			09.03.2021	09.03.2021
Lab. Sample No.			P-69	P-70
1. pH	6.5-8.5	6.5-8.5	7.46	7.41
2. Turbidity (NTU)	1	5	Nil	Nil
3. Colour (Hazen units)	5	15	None	None
4. Odour	Un Objectionable		U.O	U.O.
5. Total Alkalinity(as CaCo ₃) mg/l	200	600	130	810
6. Total Hardness (as CaCo ₃) mg/l	200	600	50	130
7. Calcium (as Ca) mg/l	75	200	5	24
8. Magnesium (as Mg) mg/l	30	100	9	17
9. Chloride (as Cl-) mg/l	250	1000	30	140
10. Nitrates (as NO ₃ -) mg/l	45	45	22	56
11. Sulphate (as SO ₄ -2) mg/l	200	400	10	55
12. Total Dissolved Solids mg/l	500	2000	287	1470
13. Fluoride mg/l	1.00	1.5	0.29	1.51
14. Iron mg/l	1.0	No Relaxation	Nil	Nil
15. Arsenic mg/l	0.01	No Relaxation	Nil	Nil

Remark- 1. All chemical parameters except pH are in mg/L


2. Tested Results Relate only to The Samples send by you


 Superintending Chemist (Heavy Metal)
 P.H.E.D. Laboratory, Jaipur

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2020-2021/

Copy to:-

1. The Chief Chemist, PHED Raj. Jaipur


 Superintending Chemist (Heavy Metal)
 P.H.E.D. Laboratory, Jaipur